



(617) 242 – 5323  
 www.mwra.com  
 PWS ID# 6000000

## INFORMATION ABOUT MWRA WATER

In cooperation with the Cambridge Water Department, the Massachusetts Water Resources Authority is pleased to send you this annual update on your drinking water quality. This report includes test results for 2022 and other important information about your tap water. The MWRA supplies wholesale water to local water departments in 50 cities and towns in greater Boston and MetroWest, and three Chicopee Valley Aqueduct (CVA) communities. MWRA water comes from Quabbin Reservoir, about 65 miles west of Boston, and Wachusett Reservoir, about 35 miles west of Boston. Water from the Ware River, located between these two reservoirs, can also add to the supply at times. The reservoirs provide about 200 million gallons of high quality water to consumers each day.

### Water Test Results

EPA requires that MWRA test for over 120 contaminants that may be in drinking water. MWRA found only those listed here. All of these levels were below EPA’s Maximum Contaminant Levels (MCL).

Test Results After Treatment Compound	Units	(MCL) Highest Level Allowed	(We Found) Detected Level-Average	Range of Detections	(MCLG) Ideal Goal	Violation	How it Gets Into Water
Barium	ppm	2	0.009	0.008-0.010	2	No	Common mineral in nature
Monochloramine	ppm	4 - MRDL	2.00	0.05 - 3.50	4 - MRDLG	No	Water disinfectant
Fluoride	ppm	4	0.679	0.385 - 0.828	4	No	Additive for dental health
Nitrite <sup>^</sup>	ppm	1	0.007	ND - 0.007	1	No	Atmospheric Deposition
Nitrate <sup>^</sup>	ppm	10	0.55	0.032 - 0.55	10	No	Atmospheric Deposition
Total Trihalomethanes	ppb	80	19.8	9.08 - 20.7	NS	No	Byproduct of water disinfection
Haloacetic Acids-5	ppb	60	19.9	4.4 - 24.4	NS	No	Byproduct of water disinfection

KEY: MCL=Maximum Contaminant Level. The highest level of a contaminant allowed in water. MCLs are set as close to the MCLGs as feasible using the best available technology. MCLG=Maximum Contaminant Level Goal. The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. MRDL=Maximum Residual Disinfectant Level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. MRDLG=Maximum Residual Disinfectant Level Goal. The level of a drinking water disinfectant below which there is no known or expected health risk. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination. ppm=parts per million ppb=parts per billion NS=no standard <sup>^</sup>=As required by DEP, the maximum result is reported for nitrate, not the average.

### More Information

If you would like to learn more about the water that MWRA supplies, about other MWRA activities and projects, about MWRA meetings that are open to the public, or for information on lead in tap water, please visit our website at [www.mwra.com](http://www.mwra.com). If you have any questions, please call 617-242-5323. Thanks for reading.