



Elizabeth Unger
Purchasing Agent

City of Cambridge

PURCHASING DEPARTMENT

SHUO WANG
Assistant Purchasing Agent for
Goods & Services

NATALIE SULLIVAN
Assistant Purchasing Agent for
Design & Construction

TO: All Bidders

FROM: City of Cambridge

DATE: February 20, 2024

RE: File No. 11386 – Haggerty School Plaza Renovation and Caulking- Addendum No. 3

This addendum is comprised of the following:

- 1. Questions and Answers**
- 2. Pre-Bid sign in sheet – 2/12/2024 (Attached)**

The following Questions were asked and answered:

Question: Can existing wall cap “precast” be reused if we can remove them without damaging them?

Answer: No, bid new as shown.

Question: Of can protect the city sidewalk to the first step, can we avoid cutting it to where it’s showing limit of aligns with the piers? That way the sidewalk would stay untouched.

Answer: Limit of work shall remain as shown.

Question: At the pre-bid meeting, it was said that the railings will only need to be reinstalled. The school would take care of repair/painting, etc. I am seeing notes calling for the railings to get refurbished. Should we bid on just reinstalling the railings after concrete is poured?

Answer: Delete any reference to “refurbish”; existing railings shall be reused as is.

All other details remain the same.

Elizabeth Unger
Purchasing Agent

Addendum No. 3



Haggerty School

Cambridge, MA

Pre-Bid Site Visit

Plaza Renovation and Caulking

February 12, 2024

Print name

Company

Email Address/Contact Info

1. Frank Geary

CPSD

fgeary@cpsd.us

2. Tito Drice

Tito Masonry & Co.

titomasonryoffice@gmail.com

3. _____

4. _____

5. _____

6. _____

7. _____

8. _____

9. _____

10. _____
