



**Cambridge tap water:**  
**Current information about PFAS testing**      **Q4 October-December 202**  
**Test Results**

PFAS Analyte	Result ng/L (ppt)
PFAS6 (regulated)	
Perfluorooctane Sulfonic Acid (PFOS)	ND
Perfluorooctanoic Acid (PFOA)	4.16
Perfluorohexane Sulfonic Acid (PFHxS)	ND
Perfluorononanoic Acid (PFNA)	ND
Perfluorohepatanoic Acid (PFHpA)	*TRACE
Perfluorodecanoic acid (PFDA)	ND
<b>Sum of PFAS6 - compare to MassDEP MCL of 20 ng/L</b>	<b>4.16</b>

MCL = Maximum Contaminant Level

ng/L = nanogram per liter

ppt = parts per trillion

ND= not detected

PFAS = Per and Poly Fluoroalkyl Substances

\*TRACE = trace amounts are present, but they are below the minimum concentration that can be reported as a quantified value.