



Elizabeth Unger
Purchasing Agent

City of Cambridge

PURCHASING DEPARTMENT

SHUO WANG
Assistant Purchasing Agent for
Goods & Services

NATALIE SULLIVAN
Assistant Purchasing Agent for
Design & Construction

TO: All Bidders

FROM: City of Cambridge

DATE: July 01, 2024

RE: File No. 11569A – War Memorial Field House Caulking - Addendum No. 1

This addendum is comprised of the following:

- 1. Question and answer**

The following question was asked and answered:

Question no. 1: What are maximum construction loads allowed on the tennis court structural slab?

Response: Per the original structural drawings the tennis court slab is designed for a maximum of 100 psf.

All other details remain the same.

Elizabeth Unger
Purchasing Agent

Addendum No. 1

