



**Elizabeth Unger**  
Purchasing Agent

# City of Cambridge

PURCHASING DEPARTMENT

**SHUO WANG**  
Assistant Purchasing Agent for  
Goods & Services

**NATALIE SULLIVAN**  
Assistant Purchasing Agent for  
Design & Construction

**TO: All Bidders**

**FROM: City of Cambridge**

**DATE: June 10, 2024**

**RE: File No. 11599 – Stony Brook Gatehouse Low Level Sluice Gate Repairs –  
Addendum No. 1**

---

**This addendum is comprised of:**

- 1. Question and Answers**

**The following questions were asked and answered:**

**Question: Will we be needing to provide a silt-boom to contain turbidity of the water during the cleaning process?**

**Answer: No.**

**Question: No mention of filtering sediment from the water following the cleaning of the vault, can we use the common filter bag then return water to reservoir or do we need to provide secondary weir tank clarifiers, then collected materials to be disposed of?**

**Answer: If necessary, a common filter bag would suffice.**

**Question: Are there existing underwater vids or pics that I can review?**

**Answer: They will be made available to the awarded contractor upon request.**

**Question: Safe to assume that the new sluice gate comes with stem support brackets and hardware?**

**Answer: No. Please review the scope.**

**All other details remain the same.**

**Elizabeth Unger**  
Purchasing Agent

**Addendum No. 1**

